


NOTE:
 AN ACCEPTED ALTERNATE IS P&L
 CONCRETE PRODUCTS PRECAST
 GREASE TRAP WITH ADDED SAMPLE
 CHAMBER ON OUTLET END AS
 SHOWN ON THIS DRAWING.

PLAN VIEW

NOTE:
 TRAFFIC LIDS TO BE INSTALLED
 IN TRAFFIC AREAS



SECTION A-A

CAPACITY GALLONS	DIMENSIONS							COVER SIZE	METAL COVERS	PIPE SIZE
	A	B	C	D	E	F	G			
510	3'-0"	9'-6"	3'-0"	2'-6"	1'-6"	4 1/2"	1'-6"	2'-10" x 3'-4"	1/4" STEEL PLATE	4"
866	3'-5"	10'-3"	4'-0"	2'-5"	2'-0"	0'-6"	1'-9"	3'-10" x 3'-10"	3/8" ALUMINUM PLATE	4"
1260	4'-0"	12'-6"	4'-0"	3'-6"	2'-0"	0'-6"	2'-0"	3'-10" x 4'-4"	3/8" ALUMINUM PLATE	4"

APPROVED BY CITY COUNCIL
 RESOLUTION NO. 2006-284

APPROVED BY THE CITY ENGINEER:
Richard D. Ull

SEWERS

GREASE & OIL INTERCEPTOR

PUBLIC WORKS DEPARTMENT

CITY of MODESTO

DETAIL NO.
512