



KITCHEN COUNTER TOP RECEPTACLE REQUIREMENTS

- * CALIFORNIA ELECTRICAL CODE SECTION 210.11(C)(1) STATES THE REQUIREMENT FOR TWO 20 AMPERE SMALL APPLIANCE BRANCH CIRCUITS.
- * CALIFORNIA ELECTRICAL CODE SECTION 210.8(A)(6) STATES THE REQUIREMENT FOR GFCI PROTECTION OF ALL KITCHEN COUNTER TOP RECEPTACLES.
- * CALIFORNIA ELECTRICAL CODE SECTION 210.52(C) STATES THE REQUIRED LOCATIONS OF KITCHEN COUNTER TOP RECEPTACLES.
- * CALIFORNIA ELECTRICAL CODE SECTIONS 210.52(C)(2), (C)(3), AND (C)(4) STATE THAT AN ELECTRICAL OUTLET IS REQUIRED FOR ISLAND AND PENINSULAR COUNTER TOPS WHEN THE LONG DIMENSION IS 24" OR GREATER AND THE SHORT DIMENSION IS 12" OR GREATER. WHERE A RANGETOP OR SINK IS INSTALLED, THE RANGETOP OR SINK IS CONSIDERED TO DIVIDE THE ISLAND AND/OR PENINSULAR COUNTER TOP INTO TWO SEPARATE COUNTER TOP SPACES.

LOCATION OF COUNTER TOP RECEPTACLES

